



HAZARDOUS WASTE TANK SYSTEM ASSESSMENT

ARIA
Heavy Metals Rinsate (HMR) System
Santa Clara, CA

Prepared for:
Apple, Inc.
1 Infinite Loop
Cupertino, California 95014

Prepared by:
TRC
10680 White Rock Road, Suite 100
Rancho Cordova, CA 95670

October 2022

HAZARDOUS WASTE TANK SYSTEM ASSESSMENT

TABLE OF CONTENTS

	<u>PAGE NO.</u>
TABLE OF CONTENTS	i
 SECTION	
I. INTRODUCTION	1
II. PURPOSE	1
III. ASSESSMENT AND FINDINGS	1
IV. CERTIFICATION	5

LIST OF FIGURES

FIGURE 1: Tank System Layout

LIST OF APPENDICES

APPENDIX A: Photographs

LIST OF ATTACHMENTS

ATTACHMENT 1: HMR-TNK-2 Information
ATTACHMENT 2: HMR-TNK-3/4 Information
ATTACHMENT 3: HMC-TNK-2 Information
ATTACHMENT 4: Leak Test Records
ATTACHMENT 5: HMR-LS and HMC-LS Information
ATTACHMENT 6: HMC-CC Information
ATTACHMENT 7: SLW-LS2 Information

I. INTRODUCTION

This assessment is specifically for the Heavy Metals Rinsate (HMR) System at the Apple, Inc. (Apple) ARIA facility (Facility), located at 3250 Scott Boulevard in Santa Clara, California.

This assessment was performed in accordance with the requirements of Section 66265.192 of Title 22 of the California Code of Regulations (22 CCR 66265.192), and included a physical inspection of the tank system and an evaluation of secondary containment. Portions of the HMR system were assessed separately in 2015 and 2019. This is a 5-year re-assessment per 22 CCR 66265.192(h)(1) to bring all systems at the facility onto the same assessment schedule.

II. PURPOSE

22 CCR 66265.192 requires that owners of a new hazardous waste tank system (subject to 22 CCR 67450.2 “Permit by Rule”) to ensure that the tank system is adequately designed and constructed, and obtain and keep on file at the Facility a written assessment reviewed and certified by an independent, qualified, professional engineer, registered in California that attests to the tank system's integrity.

The written assessment shall determine that the tank system is adequately designed and has sufficient structural strength and compatibility with the waste(s) to be transferred, stored or treated to ensure that it will not collapse, rupture, or fail.

At a minimum, the assessment for an above-ground system shall include the following information: 1) design standard(s) according to which the tank and ancillary equipment have been constructed; 2) hazardous characteristics of the waste(s) to be handled; 3) foundation and seismic anchorage design.

All new tank systems shall be tested for tightness, and determined to be free of leaks before being placed in use.

In accordance with 22 CCR 66265.192(h)(1), the assessment is valid for a maximum period of five (5) years, and shall include all of the information described in 22 CCR 66265.192(k). The required assessment information is presented in the following Section III.

III. ASSESSMENT AND FINDINGS

22 CCR 66265.192(k)(1)

The tank system consists of three lift stations (SLW-LS2, HMR-LS, HMC-LS) and the Heavy Metals Concentrate Collection Cabinet (HMC-CC) that were previously assessed and certified when newly installed in 2015, the equalization tank (HMR-TNK-2), a pH adjustment tank (HMR-TNK-3), equalization tank (HMR-TNK-4), vacuum distillation evaporator (VDE-1), heavy metal concentrate tank (HMC-TNK-2), and ancillary piping. The slurry waste lift station (SLW-LS2) is a vertical rectangular tank constructed of white polypropylene and has a primary tank capacity of 142 gallons. The heavy metal rinsate and concentrate lift stations are vertical rectangular tanks constructed of white polypropylene and have a primary tank capacity of 80 gallons and a secondary tank capacity of 110 gallons. The first equalization tank (HMR-TNK-2) is a vertical cylindrical tank constructed of high density polyethylene with a capacity of 1100 gallons. The pH adjustment tank (HMR-TNK-3) is a vertical rectangular tank constructed of

white polypropylene with a capacity of 675 gallons. The second equalization tank (HMR-TNK-4) is a vertical rectangular tank constructed of white polypropylene with a capacity of 540 gallons. HMR-TNK-3 and HMR-TNK-4 are partitions of a single horizontal rectangular tank. The heavy metal concentrate tank (HMC-TNK-2) is a vertical cylindrical tank constructed of fiberglass and vinyl ester resin (FRP) with a capacity of 2300 gallons.

22 CCR 66265.192(k)(2)

HMR-TNK-2

The first equalization tank (HMR-TNK-2) is constructed of variable thickness HDPE per ASTM D1998 design standards. Ancillary piping is Schedule 40 (SCH-40) CPVC with clear PVC containment pipe, where applicable. See Figure 1 for pipe sizes. The HMR-TNK-2 skid includes two (2) 5-hp vertical centrifugal pumps. The tank is 5 feet 4 inches in diameter and 7 feet 5 inches in height. A drawing of HMR-TNK-2, with dimensions is included in Attachment 1.

HMR-TNK-3 and HMR-TNK-4

The heavy metal rinsate pH adjustment (HMR-TNK-3) and equalization (HMR-TNK-4) tanks are constructed of ¾"-thick white polypropylene per DVS 2205 design standards. Ancillary piping is CPVC piping with clear PVC containment pipe as well as PFA tubing with clear PVC containment pipe, where applicable. See Figure 1 for pipe sizes. The heavy metal rinsate pH adjustment tank uses two (2) polypropylene pneumatic diaphragm pumps each capable of 30 GPM at 30 feet TDH using 20 SCFM of air at 40 PSI. The complete tank (HMR-TNK-3 and HMR-TNK-4) is 5 feet wide, 7 feet long, and 6 feet tall. A drawing of HMR-TNK-3&4, with dimensions is included in Attachment 2.

HMC-TNK-2

The heavy metal concentrate tank is constructed of variable thickness fiberglass and vinyl ester resin (Hexion 992) per ASTM D3299 and D4097 design standards. Tank system structural design is in accordance with CBC 2013 and ASCE 7-10. Ancillary piping is Schedule 80 (SCH-80) CPVC piping with clear PVC containment pipe, where applicable. See Figure 1 for pipe sizes. The heavy metal concentrate station is pumped out as needed using a mobile vacuum pump. The tank is 7 feet in diameter and 8 feet in height. A drawing of the tank, with dimensions, is included in Attachment 3.

HMC-LS/HMR-LS/SLW-LS2/HMC-CC

The heavy metals rinsate and concentrate lift stations, the slurry waste lift station and the heavy metals concentrate collection cabinet are constructed of ¾"-thick white polypropylene per DVS 2205 design standards. Structural design is in accordance with CBC 2013 and ASCE 7-10. Ancillary piping is Schedule 80 (SCH-80) PVC with clear PVC containment pipe, where applicable. See Figure 1 for pipe sizes. The lift stations each utilize two (2) internal 1-hp stainless steel submersible pumps. Tank drawings with dimensions are included in Attachment 5-7.

22 CCR 66265.192(k)(3)

HMR-TNK-2 and HMC-TNK-2 and their ancillary equipment were constructed in 2015, and repurposed as part of this system in 2019. HMR-TNK-3, HMR-TNK-4, and ancillary piping are newly constructed. HMR-LS, HMC-LS, HMC-CC and SLW-LS2 and their ancillary equipment were constructed in 2015

22 CCR 66265.192(k)(4)

All tanks are located on the ground level within an epoxy-coated concrete berm area. The bermed area is sloped to drain to collection sumps that are equipped with liquid sensors that would detect a leak from a tank or related ancillary piping.

The lift stations are double-walled and the space between the primary and secondary tanks is equipped with a liquid sensor that would detect a leak from the primary tank. The lift station pit is epoxy-coated and is equipped with a liquid sensor that would detect a leak from the lift stations and related ancillary piping.

The heavy metals concentrate collection cabinet is equipped with an internal liquid sensor that would detect a leak from the drums or elsewhere within the cabinet.

All automated systems, including liquid sensors for leak detection, are tested regularly to confirm operation as designed.

22 CCR 66265.192(k)(5)

The tank system is entirely above-ground and materials are not subject to corrosion.

22 CCR 66265.192(k)(6)

All tanks and lift stations are equipped with ultrasonic level sensors to prevent overflow. All automated systems, including liquid level sensors and pump controls are tested regularly to confirm operation as designed.

22 CCR 66265.192(k)(7)

All tanks and ancillary piping are located on the ground level within an epoxy-coated concrete berm area. The bermed area is sloped to drain to a collection sump and is also connected by a weir to the lift station pit (also epoxy-coated concrete) with adequate capacity to contain the full volume of the tanks. Double walled piping is also fitted with ports that would allow for collection of the leaked liquid when there is not a direct connection back to the lift stations.

The slurry waste lift (SLW-LS2) station and heavy metals lift stations (HMC-LS/HMR-LS) are set within secondary containment tanks (also ¾"-thick polypropylene) with capacity of 142 and 110 gallons, respectively. The heavy metals concentrate lift station (HMC-CC) has a secondary containment capacity of 78 gallons.

Along with the leak detection systems described above, the secondary containment for the tank system meets the standards of 22 CCR 66265.192(j) and 22 CCR 66265.193.

22 CCR 66265.192(k)(8)

The system generally handles heavy metals (potentially toxic) waste liquids generated from laboratory activities.

22 CCR 66265.192(k)(9)

No structural damage or inadequate construction/installation items (cracks, punctures, or damaged fittings) were observed.

22 CCR 66265.192(k)(10)

All ancillary pipe was leak tested using air-pressure when installed, test results are included as Attachment 4.

All tanks and lift stations were leak tested by the manufacturer prior to transport to the Facility.

22 CCR 66265.192(k)(11)

Based on the findings of this assessment, the tank system has an estimated remaining service life of approximately 20 years under existing conditions. The estimated remaining service life should be re-evaluated every five (5) years, in conjunction with the re-assessment in accordance with the requirements of 22 CCR 66265.192(h)(1).

IV. CERTIFICATION

ARIA Heavy Metals Rinsate System October 2022

22 CCR 66265.192 requires that owners of a new hazardous waste tank system (subject to 22 CCR 67450.2 "Permit by Rule") ensure that the tank system is adequately designed and constructed, and obtain and keep on file at the Facility a written assessment reviewed and certified by an independent, qualified, professional engineer, registered in California that attests to the tank system's integrity.

The preceding written assessment has determined that the tank system is adequately designed and has sufficient structural strength and compatibility with the waste(s) to be transferred, stored or treated to ensure that it will not collapse, rupture, or fail. This assessment for an above-ground system considered the following: 1) design standard(s) according to which the tank and ancillary equipment have been constructed; 2) hazardous characteristics of the waste(s) to be handled; 3) foundation and seismic anchorage design.

The tank system was inspected on October 19, 2022. The visual inspection found none of the following to be in evidence: leaks, weld breaks, punctures, scrape of protective coatings, cracks, corrosion, structural damage or installation defects.

As required by 22 CCR 66265.192(k)(11), based on the findings of this assessment, I estimate that the new tank system has at least twenty (20) years of service life under current conditions. In accordance with 22 CCR 66265.192(h)(1), this assessment is valid for a maximum period of five (5) years and the tank system should be re-assessed at that time to obtain a new estimate of remaining service life.

Based on my assessment of the tank system, I can attest that the tank system has sufficient structural integrity, is acceptable for transferring, storing and treating the intended hazardous waste, and is suitably designed to achieve the requirements under 22 CCR 66265.192.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



Stephen V. Huvane, P.E.
Civil (CA) No. 52385




12/21/22

Date


FIGURE 1

TANK SYSTEM LAYOUT



- NOTES**
- HMR-TNK-2 ANCILLARY PIPING IS SCHEDULE 40 (SCH-40) CPVC WITH CLEAR PVC CONTAINMENT PIPE.
 - HMR-TNK-3&4 ANCILLARY PIPING IS SCHEDULE 80 (SCH-80) CPVC WITH CLEAR PVC CONTAINMENT PIPE FOR WATER LINES AND PFA TUBING WITH CLEAR PVC CONTAINMENT PIPE FOR pH CONTROL FEED CHEMICALS.
 - HMC-TNK-2 ANCILLARY PIPING IS SCHEDULE 80 (SCH-80) CPVC PIPING WITH CLEAR PVC CONTAINMENT PIPE

SLW-LS2
HMR-LS
HMC-LS
HMC-CC



LEGEND
— SYSTEM COMPONENTS ASSESSED


TANK SYSTEM LAYOUT HEAVY METAL RINSATE SYSTEM




FIGURE 1

APPENDIX A

PHOTOGRAPHS
(OCTOBER 19, 2022)



Slurry Waste Lift Station (SLW-LS2) in Containment Pit



Heavy Metal Rinsate and Concentrate Lift Stations in Containment Pit



HMR-TNK-2



Heavy Metals Concentrate Collection Cabinet (HMC-CC)



HMR-TNK-3&4 and piping to Vacuum Distillation Evaporator (VDE-1)



Piping from HMR-TNK-3 to VDE-1





Piping to VDE-1 (left) and piping to HMC-TNK-2 (right)



HMC-TNK-2 and piping to Heavy Metal Concentrate Pull Station (HMC-TFS-1)

ATTACHMENT 1

HMR-TNK-2 INFORMATION



*ALL EXTERNAL PIPING MUST BE INDEPENDENTLY SUPPORTED.
 *ONLY BASE FITTINGS TO BE LEFT INSTALLED AT TIME OF SHIPMENT PER SII PROCEDURE.
 *Consult Snyder's Guidelines for Use and Installation prior to delivery.
 Available on-line at <http://www.snyderindustriestanks.com/Technical>
 ALL DIMENSIONS ARE IN INCHES, NOMINAL, & SUBJECT TO CHANGE WITHOUT NOTICE.
 ALL DIMENSIONS ON ROTATIONAL MOLDED PARTS ARE SUBJECT TO A ± 3% TOLERANCE.


DO NOT SCALE	DRAWN BY	DATE
STATUS: Released	ET3	07/30/2013
© SNYDER INDUSTRIES INC., 2014		
ALL DIMENSIONS, DESIGNS, AND INFORMATION ON THIS PRINT MUST BE CONSIDERED PROPRIETARY TO SNYDER INDUSTRIES, INC. AND MAY NOT BE USED, COPIED, OR DISTRIBUTED WITHOUT WRITTEN PERMISSION OF AN OFFICER (OR HIS AGENT) OF THE FIRM.		

SII SNYDER INDUSTRIES, INC.
4700 Fremont Street Lincoln, NE 68504 (402) 467-5221 www.snyder.net


TITLE:	REVISION
ASM TK 1100VDT X 64	A
PART NO.	ENG. ID.
1830000N__01	D001111
SHEET 1 OF 1	

ATTACHMENT 2


HMR-TNK-3&4 INFORMATION




DETAIL A



PLAN VIEW



SIDE VIEW



ELEVATION VIEW

FABRICATION STATUS

PLEASE CHECK BOX AND SIGN WHEN COMPLETED

- ☐ COMPLETED NO CHANGES
- ☐ COMPLETED PER REDLINE CHANGES
- ☐ NOT COMPLETED, DESIGN CHANGES REQUIRED

NAME DATE

- NOTES:
1. PRIMARY TANK SHALL BE FABRICATED FROM 3/4" THICK POLYPROPYLENE.
 2. ALL PIPING AND FITTINGS TO BE CPVC SCH 80.
 3. ALL SURFACES TO BE SEALED WITH EPDM GASKET TAPE.
 4. SOME SUPPORTS NOT SHOWN FOR CLARITY

REV.	DATE:	BY:	DESCRIPTION
0	11/21/2018	JB	ISSUED FOR FABRICATION
APPROVALS			DATE
DRAWN BY: JB			11/21/2018
CHECKED BY: JB			11/21/2018
APPROVED BY: SS			11/21/2018

PROPRIETARY INFORMATION

©2018 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE
PROPERTY OF WASTECH CONTROLS & ENGINEERING INC.
ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE
WITHOUT WRITTEN CONSENT IS PROHIBITED.





TITLE: APPLE, INC. - ARIA 500 GALLON PRODELTA BATCH MECHANICAL FABRICATION		REVISION 0
SIZE B	DWG. NO. 181320-MF-102	
SCALE: NTS		SHEET: 2 OF 4

ATTACHMENT 3


HMC-TNK-2 INFORMATION

ISOMETRIC VIEW




PLAN VIEW


LIT-HMR-TNK-2-1
(TO BE WIRED
TO HMR-LS
CONTROL PANEL)



LEFT ELEVATION VIEW



FRONT ELEVATION VIEW



RIGHT ELEVATION VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET FROM GW-LS
N2	3" FLANGE	1	INLET FROM SWS-LS
N3	3" FLANGE	1	INLET FROM HMR DIVERSION
N4	3" FLANGE	5	SPARE
N5	4" FLANGE	1	VENT
N6	3" FLANGE	1	OVERFLOW
N7	1" FNPT	1	SAMPLE PORT
N8	3" FLANGE	1	SUCTION PORT

- NOTES:
- MATERIALS OF CONSTRUCTION:
A) TANK TO BE FABRICATED FROM FRP.
B) ALL PIPING AND FITTINGS TO BE CPVC SCH 80.
C) HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH EPDM GASKET.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SIZED BY WASTECH, PROVIDED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANKS.
 - APPROXIMATE EQUIPMENT WEIGHTS:**
A) DRY WEIGHT: 2000 LBS
B) OPERATING WEIGHT: 23000 LBS

REV.	DATE:	BY:	DESCRIPTION
4	03/31/2015	MF	ISSUED FOR FABRICATION
3	01/30/2015	MF	RESUBMITTED FOR APPROVAL
2	01/13/2015	MF	RESUBMITTED FOR APPROVAL
1	12/02/2014	MF	SUBMITTED FOR APPROVAL
0	10/21/2014	MF	DRAFT

APPROVALS		DATE
DRAWN BY: MF		10/21/2014
PROJECT ENG.: JB		
ENGINEERING MANAGER: SS		

PROPRIETARY INFORMATION
©2014 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE
PROPERTY OF WASTECH CONTROLS & ENGINEERING INC.
ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE
WITHOUT WRITTEN CONSENT IS PROHIBITED.



TITLE: ARIA HEAVY METALS RINSE DIVERSION TANK MECHANICAL GENERAL ARRANGEMENT	REVISION 4
--	---------------

SIZE B	DWG. NO. 141190-MG-701
-----------	---------------------------

SCALE: NTS	SHEET: 1 OF 3
------------	---------------

ATTACHMENT 4

LEAK TEST RECORDS

MULTIPLE SYSTEMS PRESSURE RETENTION TESTS REPORT
AS OF 4/16/2019
(READ ONLY/PRINT)

PROPOSAL # 20826
REPORT DATE 3/21/2017
REPORT # 1245

Total Number of Proposals Found = 39

CLIENT: ARIA / Apple

CONTRACTOR: Murray Company

TEST LOCATION: ARIA - 3250 Scott Blvd. - Santa Clara / Mechanical Yard

TOOL: Waste Systems

SYSTEM	WORKING PRESSURE	START		FINISH		PASS	FAIL
		PRESSURE	TIME	PRESSURE	TIME		
Heavy Metal Rinse: Tested 2" Primary CPVC Line from HMR-Tank-2 POC to HMR-VMB-2 & to HMC-Tank -2 POC.	NA	56psi	6:00am	56psi	7:00am	DM	
Heavy Metal Rinse: Tested 4" Containment Line from HMR-Tank-2 POC to HMR-VMB-2 & to HMC-Tank -2 POC.	NA	6psi	6:00am	6psi	7:00am	DM	
Heavy Metal Concentrate: Tested 1" to 2" Primary CPVC Line from VDE-1 POC to Main & HMC-Tank-2 POC.	NA	58psi	6:00am	58psi	7:00am	DM	
Heavy Metal Concentrate: Tested 4" Containment Line from VDE-1 POC to Main & HMC-Tank-2 POC.	NA	6psi	6:00am	6psi	7:00am	DM	
Sodium Hydroxide: Tested 1/2" Primary PFA Line from Lift Station POC to HMR-Tank-3 POC.	NA	150psi	6:00am	150psi	7:00am	DM	
Sodium Hydroxide: Tested 2" Containment Line from Lift Station POC to HMR-Tank-3 POC.	NA	6psi	6:00am	6psi	7:00am	DM	

TYPE: PNEUMATIC ☒ HYDROSTATIC ☐ MEDIA Nitrogen

TEST GAUGE: MAKE Exsel SERIAL # 49899, 49829, 52218, PSIG: 0-200, 0-200, 0-15PSI

COMMENTS: SENSITIVITY: 1psi CALIBRATION DUE DATE: 1/10/20 & 2/27/20

TEST WITNESSED BY: Demar Mills

TEST DATE: 3/21/2017

TEST PERFORMED BY: MURRAY COMPANY

DATE: 3/21/2017

MULTIPLE SYSTEMS PRESSURE RETENTION TESTS REPORT
AS OF 4/16/2019
(READ ONLY/PRINT)

PROPOSAL # 20826
REPORT DATE 3/21/2017
REPORT # 1246

Total Number of Proposals Found = 39

CLIENT: ARIA / Apple CONTRACTOR: Murray Company

TEST LOCATION: ARIA - 3250 Scott Blvd. - Santa Clara / Mechanical Yard

TOOL: Waste Systems

SYSTEM	WORKING PRESSURE	START		FINISH		PASS	FAIL
		PRESSURE	TIME	PRESSURE	TIME		
Sulfuric Acid: Tested 1/2" Primary PFA Line from Lift Station POC to HMR-Tank-3 POC.	NA	150psi	6:00am	150psi	7:00am	DM	
Sulfuric Acid: Tested 2" Containment Line from Lift Station POC to HMR-Tank-3 POC.	NA	6psi	6:00am	6psi	7:00am	DM	

TYPE: PNEUMATIC ☒ HYDROSTATIC ☐ MEDIA Nitrogen
TEST GAUGE: MAKE Perma Cal SERIAL # CN4292 PSIG: 0-300PSI
COMMENTS: SENSITIVITY: 1psi CALIBRATION DUE DATE: 2/11/10

TEST WITNESSED BY: Demar Mills

TEST DATE: 3/21/2017

TEST PERFORMED BY: MURRAY COMPANY

DATE: 3/21/2017

MULTIPLE SYSTEMS PRESSURE RETENTION TESTS REPORT
AS OF 4/16/2019
(READ ONLY/PRINT)

PROPOSAL # 20826
REPORT DATE 3/21/2017
REPORT # 1243

Total Number of Proposals Found = 39

CLIENT: ARIA / Apple

CONTRACTOR: Murray Company

TEST LOCATION: ARIA - 3250 Scott Blvd. - Santa Clara / Mechanical Yard

TOOL: Waste Systems

SYSTEM	WORKING PRESSURE	START		FINISH		PASS	FAIL
		PRESSURE	TIME	PRESSURE	TIME		
Heavy Metal Rinse: Tested 1" Primary CPVC Line from HMR-Tank-3 POC to VDE-1 POC.	NA	52psi	6:00am	52psi	7:00am	DM	
Heavy Metal Rinse: Tested 4" Containment Line from HMR-Tank-3 POC to VDE-1 POC.	NA	5psi	6:00am	5psi	7:00am	DM	
Heavy Metal Rinse: Tested 1 1/2" Primary CPVC Line from HMR-Lift Station POC to HMR-VMB-1 to HMR-Tank-2 POC.	NA	51psi	6:00am	51psi	7:00am	DM	
Heavy Metal Rinse: Tested 4" Containment Line from HMR-Lift Station POC to HMR-VMB-1 to HMR-Tank-2 POC.	NA	5psi	6:00am	5psi	7:00am	DM	
Heavy Metal Rinse: Tested 1 1/2" Primary CPVC Line from HMR-Lift Station POC to HMR-VMB-1 to HMC-Tank-2 POC.	NA	51psi	6:00am	51psi	7:00am	DM	
Heavy Metal Rinse: Tested 4" Containment Line from HMR-Lift Station POC to HMR-VMB-1 to HMC-Tank-2 POC	NA	5psi	6:00am	5psi	7:00am	DM	

TYPE: PNEUMATIC ☒ HYDROSTATIC ☐ MEDIA Nitrogen

TEST GAUGE: MAKE Exsel SERIAL # 49899, 49829, 52218, PSIG: 0-200, 0-200, 0-15PSI

COMMENTS: SENSITIVITY: 1psi CALIBRATION DUE DATE: 1/10/20 & 2/27/20

TEST WITNESSED BY: Demar Mills

TEST DATE: 3/21/2017

TEST PERFORMED BY: MURRAY COMPANY

DATE: 3/21/2017

MULTIPLE SYSTEMS PRESSURE RETENTION TESTS REPORT
AS OF 4/16/2019
(READ ONLY/PRINT)

PROPOSAL # 20826
REPORT DATE 3/21/2017
REPORT # 1244

Total Number of Proposals Found = 39

CLIENT: ARIA / Apple

CONTRACTOR: Murray Company

TEST LOCATION: ARIA - 3250 Scott Blvd. - Santa Clara / Mechanical Yard

TOOL: Waste Systems

SYSTEM	WORKING PRESSURE	START		FINISH		PASS	FAIL
		PRESSURE	TIME	PRESSURE	TIME		
Slurry Waste / Heavy Metal Rinse: Tested 2" Primary CPVC Line from SLW/HMR-1 VMB POC to HMR-Tank-2 POC.	NA	55psi	6:00am	55psi	7:00am	DM	
Slurry Waste / Heavy Metal Rinse: Tested 4" Containment Line from SLW/HMR-1 VMB POC to HMR-Tank-2 POC.	NA	6psi	6:00am	6psi	7:00am	DM	
Slurry Waste / Heavy Metal Rinse: Tested 2" Primary CPVC Line from SLW/HMR-1 VMB POC to HMC-Tank-2 POC.	NA	55psi	6:00am	55psi	7:00am	DM	
Slurry Waste / Heavy Metal Rinse: Tested 4" Containment Line from SLW/HMR-1 VMB POC to HMC-Tank-2 POC.	NA	6psi	6:00am	6psi	7:00am	DM	
Heavy Metal Rinse: Tested 2" Primary CPVC Line from HMR-Tank-2 POC to HMR-VMB-2 & to HMR-Tank -3 POC.	NA	56psi	6:00am	56psi	7:00am	DM	
Heavy Metal Rinse: Tested 4" Containment Line from HMR-Tank-2 POC to HMR-VMB-2 & to HMR-Tank -3 POC.	NA	6psi	6:00am	6psi	7:00am	DM	

TYPE: PNEUMATIC ☒ HYDROSTATIC ☐ MEDIA Nitrogen

TEST GAUGE: MAKE Exsel SERIAL # 49899, 49829, 52218, PSIG: 0-200, 0-200, 0-15PSI

COMMENTS: SENSITIVITY: 1psi CALIBRATION DUE DATE: 1/10/20 & 2/27/20

TEST WITNESSED BY: Demar Mills


TEST DATE: 3/21/2017

TEST PERFORMED BY: MURRAY COMPANY


DATE: 3/21/2017

ATTACHMENT**5**


LIFT STATION (HMC-LS and HMR-LS) INFORMATION




PLAN VIEW




ELEVATION VIEW




SECTION B-B
(INVERTED TIE-DOWN)



SECTION A-A
(TIE-DOWN)



ISOMETRIC VIEW



SIDE ELEVATION VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	1-1/2" FNPT	1	DISCHARGE
N3	4" FNPT	1	DOUBLE CONTAINMENT
N4	2" FNPT	1	VENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1" FNPT	1	CONTAINMENT TANK DRAIN
N7	1/2" FNPT	1	CDA TO HMR-PMP-1A
N8	1/2" FNPT	1	CDA TO HMR-PMP-1B
N9	1/4" FNPT	1	CDA TO PD HMR-TNK-1-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
A) TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
B) ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC
C) ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
D) HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SIZED BY WASTECH, SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:
A) DRY WEIGHT: 510 LB
B) OPERATING WEIGHT: 1110 LB
C) MAXIMUM WEIGHT: 1250 LBS
 - PRIMARY TANK VOLUME: 80 GAL
CONTAINMENT TANK VOLUME: 110 GAL


REV.	DATE:	BY:	DESCRIPTION
3	4/15/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL

APPROVALS		DATE
DRAWN BY:	MM	12/12/2014
PROJECT ENG.:	SS	
ENGINEERING MANAGER:	SS	


PROPRIETARY INFORMATION
©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.




TITLE: ARIA HEAVY METAL RINSE PUMP LIFT STATION (HMR-LS) MECHANICAL GENERAL ARRANGEMENT		REVISION 3
SIZE B	DWG. NO. 141-190-MG-501	
SCALE: NTS		SHEET: 1 OF 3




PLAN VIEW




FRONT ISOMETRIC VIEW
(REMOVABLE ENCLOSURE DETAIL)




FRONT ISOMETRIC VIEW



ELEVATION VIEW



DETAIL A



REAR ISOMETRIC VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	1-1/2" FNPT	1	DISCHARGE
N3	4" FNPT	1	DOUBLE CONTAINMENT
N4	2" FNPT	1	VENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1" FNPT	1	CONTAINMENT TANK DRAIN
N7	1/2" FNPT	1	CDA TO HMR-PMP-1A
N8	1/2" FNPT	1	CDA TO HMR-PMP-1B
N9	1/4" FNPT	1	CDA TO PD HMR-TNK-1-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
A) TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
B) ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC
C) ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
D) HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SIZED BY WASTECH, SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:
A) DRY WEIGHT: 510 LB
B) OPERATING WEIGHT: 1110 LB
C) MAXIMUM WEIGHT: 1250 LBS
 - PRIMARY TANK VOLUME: 80 GAL
CONTAINMENT TANK VOLUME: 110 GAL

REV.	DATE:	BY:	DESCRIPTION
3	6/08/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL


APPROVALS		DATE
DRAWN BY:	MM	12/12/2014
PROJECT ENG.:	JB	
ENGINEERING MANAGER:	SS	

PROPRIETARY INFORMATION

©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.




TITLE: ARIA HEAVY METAL RINSE PUMP LIFT STATION (HMR-LS) MECHANICAL GENERAL ARRANGEMENT		REVISION 3
SIZE B	DWG. NO. 141190-MG-502	
SCALE: NTS		SHEET: 2 OF 3




PLAN VIEW

PRIMARY TANK
VOLUME: 80 GAL




ELEVATION VIEW



PLAN VIEW

CONTAINMENT TANK
VOLUME: 110 GAL



ELEVATION VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	1-1/2" FNPT	1	DISCHARGE
N3	4" FNPT	1	DOUBLE CONTAINMENT
N4	2" FNPT	1	VENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1" FNPT	1	CONTAINMENT TANK DRAIN
N7	1/2" FNPT	1	CDA TO HMR-PMP-1A
N8	1/2" FNPT	1	CDA TO HMR-PMP-1B
N9	1/4" FNPT	1	CDA TO PD HMR-TNK-1-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
A) TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
B) ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC
C) ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
D) HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SIZED BY WASTECH, SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:**
A) DRY WEIGHT: 510 LB
B) OPERATING WEIGHT: 1110 LB
C) MAXIMUM WEIGHT: 1250 LBS
 - PRIMARY TANK VOLUME: 80 GAL
CONTAINMENT TANK VOLUME: 110 GAL

REV.	DATE:	BY:	DESCRIPTION
3	4/15/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL


APPROVALS		DATE
DRAWN BY: MM		12/12/2014
PROJECT ENG.: JB		
ENGINEERING MANAGER: SS		

PROPRIETARY INFORMATION
©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.




TITLE: ARIA HEAVY METAL RINSE PUMP LIFT STATION (HMR-LS) MECHANICAL GENERAL ARRANGEMENT		REVISION 3
---	--	---------------



SIZE B	DWG. NO. 141190-MG-503
-----------	---------------------------




SECTION B-B
(INVERTED TIE-DOWN)




ISOMETRIC VIEW



SECTION A-A
(TIE-DOWN)



SIDE ELEVATION VIEW



NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	1-1/2" FNPT	1	DISCHARGE
N3	4" FNPT	1	DOUBLE CONTAINMENT
N4	2" FNPT	1	VENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1" FNPT	1	CONTAINMENT TANK DRAIN
N7	1/2" FNPT	1	CDA TO HMC-PMP-1A
N8	1/2" FNPT	1	CDA TO HMC-PMP-1B
N9	1/4" FNPT	1	CDA TO PD HMC-TNK-1-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
A) TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
B) ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC
C) ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
D) HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SIZED BY WASTECH, SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:
A) DRY WEIGHT: 510 LB
B) OPERATING WEIGHT: 1110 LB
C) MAXIMUM WEIGHT: 1250 LBS
 - PRIMARY TANK VOLUME: 80 GAL
CONTAINMENT TANK VOLUME: 110 GAL

REV.	DATE:	BY:	DESCRIPTION
3	6/08/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL


APPROVALS		DATE
DRAWN BY:	MM	12/12/2014
PROJECT ENG.:	SS	
ENGINEERING MANAGER:	SS	

PROPRIETARY INFORMATION


©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC.
ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.




TITLE: ARIA CONCENTRATED METAL PUMP LS (HMC-LS) MECHANICAL GENERAL ARRANGEMENT		REVISION 3
SIZE B	DWG. NO. 141-193-MG-111	
SCALE: NTS		SHEET: 1 OF 3




PLAN VIEW




FRONT ISOMETRIC VIEW
(REMOVABLE ENCLOSURE DETAIL)




FRONT ISOMETRIC VIEW



ELEVATION VIEW



DETAIL A



REAR ISOMETRIC VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	1-1/2" FNPT	1	DISCHARGE
N3	4" FNPT	1	DOUBLE CONTAINMENT
N4	2" FNPT	1	VENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1" FNPT	1	CONTAINMENT TANK DRAIN
N7	1/2" FNPT	1	CDA TO HMC-PMP-1A
N8	1/2" FNPT	1	CDA TO HMC-PMP-1B
N9	1/4" FNPT	1	CDA TO PD HMC-TNK-1-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
A) TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
B) ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC
C) ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
D) HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SIZED BY WASTECH, SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:
A) DRY WEIGHT: 510 LB
B) OPERATING WEIGHT: 1110 LB
C) MAXIMUM WEIGHT: 1250 LBS
 - PRIMARY TANK VOLUME: 80 GAL
CONTAINMENT TANK VOLUME: 110 GAL


REV.	DATE:	BY:	DESCRIPTION
3	6/08/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL

APPROVALS		DATE
DRAWN BY:	MM	12/12/2014
PROJECT ENG.:	SS	
ENGINEERING MANAGER:	SS	

PROPRIETARY INFORMATION
©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.




TITLE: ARIA CONCENTRATED HEAVY METAL PUMP LS (HMC-LS) MECHANICAL GENERAL ARRANGEMENT		REVISION 3
SIZE B	DWG. NO. 141193-MG-112	
SCALE: NTS		SHEET: 2 OF 3




PLAN VIEW

PRIMARY TANK
VOLUME: 80 GAL




ELEVATION VIEW



PLAN VIEW

CONTAINMENT TANK
VOLUME: 110 GAL



ELEVATION VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	1-1/2" FNPT	1	DISCHARGE
N3	4" FNPT	1	DOUBLE CONTAINMENT
N4	2" FNPT	1	VENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1" FNPT	1	CONTAINMENT TANK DRAIN
N7	1/2" FNPT	1	CDA TO HMC-PMP-1A
N8	1/2" FNPT	1	CDA TO HMC-PMP-1B
N9	1/4" FNPT	1	CDA TO PD HMC-TNK-1-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
 - TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
 - ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC
 - ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
 - HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SIZED BY WASTECH, SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:**
 - DRY WEIGHT: 510 LB
 - OPERATING WEIGHT: 1110 LB
 - MAXIMUM WEIGHT: 1250 LBS
 - PRIMARY TANK VOLUME: 80 GAL
CONTAINMENT TANK VOLUME: 110 GAL

REV.	DATE:	BY:	DESCRIPTION
3	6/08/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL

APPROVALS		DATE
DRAWN BY: MM		12/12/2014
PROJECT ENG.: SS		
ENGINEERING MANAGER: SS		


PROPRIETARY INFORMATION
©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.




TITLE: ARIA CONCENTRATED HEAVY METAL PUMP LS (HMC-LS) MECHANICAL GENERAL ARRANGEMENT		REVISION 3
SIZE B	DWG. NO. 141193-MG-113	
SCALE: NTS		SHEET: 3 OF 3

ATTACHMENT 6


COLLECTION CABINET (HMC-CC) INFORMATION




PLAN VIEW




DETAIL A




ISOMETRIC VIEW



FRONT ELEVATION VIEW



SIDE ELEVATION VIEW



DETAIL A

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	1-1/2" FNPT	1	WASTEWATER INLET
N2	4" FNPT	1	DOUBLE CONTAINMENT
N3	4" FNPT	1	CABINET VENT
N4	3/8" FNPT	2	CDA INLET
N5	1" FNPT	1	DRAIN

- NOTES:
- MATERIALS OF CONSTRUCTION
A) CABINET TO BE FABRICATED FROM 3/4" WHITE POLYPROPYLENE.
B) ROLLERS TO BE FABRICATED FROM STAINLESS STEEL.
C) ALL PIPING AND FITTINGS TO BE CPVC EXCEPT WHERE NOTED.
D) PNEUMATIC TUBING TO BE POLYURETHANE.
 - CHEMICAL DRUMS TO BE PROVIDED BY OTHERS.
 - ANCHOR BOLTS TO BE SIZED BY WASTECH, SUPPLIED AND INSTALLED BY OTHERS.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE CABINET.
 - VOLUME OF DOUBLE CONTAINMENT: 78 GALLONS
 - APPROXIMATE EQUIPMENT WEIGHTS:
A) DRY WEIGHT: 790 LBS
B) OPERATING WEIGHT: 1670 LBS
C) MAXIMUM WEIGHT: 2230 LBS

REV.	DATE:	BY:	DESCRIPTION
3	4/30/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL

APPROVALS		DATE
DRAWN BY: MM		12/12/2014
PROJECT ENG.: SS		
ENGINEERING MANAGER: SS		

PROPRIETARY INFORMATION
©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.




TITLE: ARIA CHEMICAL COLLECTION CABINET (HMC-CC-1) MECHANICAL GENERAL ARRANGEMENT	REVISION 3
---	---------------


SIZE B	DWG. NO. 141193-MG-101
SCALE: NTS	SHEET: 1 OF 1

ATTACHMENT 7


LIFT STATION (SLW-LS2) INFORMATION




PLAN VIEW




SECTION B-B
(INVERTED TIE-DOWN)




ISOMETRIC VIEW



ELEVATION VIEW



SECTION A-
(TIE-DOWN)



SIDE ELEVATION VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	2" FNPT	1	VENT
N3	2" FNPT	1	PUMPED DISCHARGE
N4	4" FNPT	1	DOUBLE CONTAINMENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1/2" FNPT	1	CDA TO SLW-PMP-2A
N7	1/2" FNPT	1	CDA TO SLW-PMP-2B
N8	1/4" FNPT	1	CDA TO PD SLW-TNK-2-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
 - A) TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
 - B) ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC.
 - C) ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
 - D) HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:
 - A) DRY WEIGHT: 620 LBS
 - B) OPERATING WEIGHT: 1700 LBS
 - C) MAXIMUM WEIGHT: 1885 LBS
 - TANK VOLUME: 142 GAL


REV.	DATE:	BY:	DESCRIPTION
4	7/07/2015	MM	REVISED AS BUILT
3	5/02/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL

APPROVALS		DATE
DRAWN BY: MM		09/09/2014
PROJECT ENG.: SS		
ENGINEERING MANAGER: SS		


PROPRIETARY INFORMATION
©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.




TITLE: ARIA GRINDER AREA LIFT STATION (SLW-LS2) MECHANICAL GENERAL ARRANGEMENT		REVISION 4
SIZE B	DWG. NO. 141193-MG-211	
SCALE: NTS		SHEET: 1 OF 3




FRONT ISOMETRIC VIEW
(REMOVABLE ENCLOSURE DETAIL)



ELEVATION VIEW



PLAN VIEW



REAR ISOMETRIC VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	2" FNPT	1	VENT
N3	2" FNPT	1	PUMPED DISCHARGE
N4	4" FNPT	1	DOUBLE CONTAINMENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1/2" FNPT	1	CDA TO SLW-PMP-2A
N7	1/2" FNPT	1	CDA TO SLW-PMP-2B
N8	1/4" FNPT	1	CDA TO PD SLW-TNK-2-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
 - TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
 - ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC.
 - ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
 - HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:**
 - DRY WEIGHT: 620 LBS
 - OPERATING WEIGHT: 1700 LBS
 - MAXIMUM WEIGHT: 1885 LBS
 - TANK VOLUME: 142 GAL

REV.	DATE:	BY:	DESCRIPTION
4	7/07/2015	MM	REVISED AS BUILT
3	6/08/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL


APPROVALS		DATE
DRAWN BY:	MM	09/22/2014
PROJECT ENG.:	SS	
ENGINEERING MANAGER:	SS	

PROPRIETARY INFORMATION
©2015 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE
PROPERTY OF WASTECH CONTROLS & ENGINEERING INC.
ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE
WITHOUT WRITTEN CONSENT IS PROHIBITED.



TITLE:	ARIA GRINDER AREA LIFT STATION (SLW-LS2) MECHANICAL GENERAL ARRANGEMENT	REVISION 4
--------	---	---------------


SIZE B	DWG. NO. 141193-MG-212
-----------	---------------------------




PLAN VIEW

CONTAINMENT TANK

VOLUME: 142 GAL




ELEVATION VIEW



PLAN VIEW

PRIMARY TANK

VOLUME: 116 GAL



ELEVATION VIEW

NOZZLE SCHEDULE			
NOZZLE	DESCRIPTION	QTY	SERVICE
N1	3" FLANGE	1	INLET
N2	2" FNPT	1	VENT
N3	2" FNPT	1	PUMPED DISCHARGE
N4	4" FNPT	1	DOUBLE CONTAINMENT
N5	2" FNPT	2	PLUGGED OVERFLOW
N6	1/2" FNPT	1	CDA TO SLW-PMP-2A
N7	1/2" FNPT	1	CDA TO SLW-PMP-2B
N8	1/4" FNPT	1	CDA TO PD SLW-TNK-2-1

- NOTES:
- MATERIALS OF CONSTRUCTION:
A) TANKS TO BE FABRICATED FROM 3/4" THICK WHITE POLYPROPYLENE.
B) ACCESS DOORS AND HATCHES TO BE 1/4" THICK CLEAR PVC.
C) ALL PIPING AND FITTINGS TO BE SCH 80 CPVC.
D) HARDWARE TO BE 18-8 SS.
 - ALL SURFACES TO BE SEALED WITH PTFE GASKET TAPE.
 - SOME SUPPORTS NOT SHOWN FOR CLARITY. ANCHOR BOLTS TO BE SUPPLIED AND INSTALLED BY OTHERS.
 - INSTALLATION, INTERCONNECTING PIPING AND WIRING SUPPLIED AND INSTALLED BY OTHERS. INSTALLER TO PROVIDE ADEQUATE VENTILATION TO THE TANK.
 - APPROXIMATE EQUIPMENT WEIGHTS:**
A) DRY WEIGHT: 620 LBS
B) OPERATING WEIGHT: 1700 LBS
C) MAXIMUM WEIGHT: 1885 LBS
 - TANK VOLUME: 142 GAL

REV.	DATE:	BY:	DESCRIPTION
4	7/07/2015	MM	REVISED AS BUILT
3	6/08/2015	MM	AS BUILT
2	3/31/2015	MM	ISSUED FOR FABRICATION
1	1/22/2015	MM	RESUBMITTED FOR APPROVAL
0	12/12/2014	MM	SUBMITTED FOR APPROVAL

APPROVALS		DATE
DRAWN BY: MM		09/22/2014
PROJECT ENG.: JB		
ENGINEERING MANAGER: SS		

PROPRIETARY INFORMATION

©2014 WASTECH CONTROLS & ENGINEERING, INC.
THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF WASTECH CONTROLS & ENGINEERING INC. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE WITHOUT WRITTEN CONSENT IS PROHIBITED.



TITLE:	ARIA GRINDER AREA LIFT STATION (SLW-LS2) MECHANICAL GENERAL ARRANGEMENT	REVISION 4
--------	---	---------------

SIZE B	DWG. NO. 141193-MG-213
-----------	---------------------------